



DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI , DELHI-110041



Water Samples collected from "Dharam Deep Sec. Public School" J-Block, Adhyapak Nagar, Najafgarh Road, Nangloi, New Delhi – 110041 Vide challan no :-163 dated:- 22.02.2024
S1:- Drinking Point at above site.

S. No	Parameter	Units	Limit		S1
			Acceptable	Permissible	
PHYSICAL EXAMINATION					
1.	Date of collection	-----	--	--	09.03.2024
2.	Date of Analysis	-----	--	--	12.03.2024
3.	Colour	Hazen	5.0	15	Clear
4.	Odour	-----	No. Objectionable		No Obj.
5.	Turbidity	N.T.U.	1.0	5.0	1.21
6.	PH value	-----	6.5	8.5	7.52
7.	Electrical Conductivity	µmho	--	--	442.3
8.	Total dissolved solids	mg/l	500	2000	287.49
CHEMICAL EXAMINATION					
9.	p th Alkalinity	mg/l	--	--	NIL
10.	Total Alkalinity	mg/l	200	600	128
11.	Total Hardness	mg/l	200	600	164
12.	Calcium Hardness	mg/l	--	--	98
13.	Magnesium Hardness	mg/l	--	--	66
14.	Calcium as Ca	mg/l	75	200	39.2
15.	Magnesium as Mg	mg/l	30	100	15.84
16.	Ammonia as N	mg/l	0.5	N.R.	0.08
17.	Nitrite as N	mg/l	---	--	0.010
18.	Nitrate as NO ₃	mg/l	45	N.R.	-
19.	Sulphate	mg/l	200	400	26
20.	Chloride	mg/l	250	1000	44
21.	Dissolved Iron	mg/l	0.3	N.R.	0.06
22.	Fluoride	mg/l	1	1.5	0.24
23.	Cyanide	mg/l	0.05	N.R.	ND
24.	Residual Chlorine	mg/l	0.20	1.0	0.50
BACTERIOLOGICAL EXAMINATION					
25.	Coli-form per 100 ml at 37°C	MPN	0		0

REMARKS: As per tested parameters Sample – S1 can be used for drinking purpose.

Sapender
ACWA
Asstt. Chief Water Analyst
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works Nangloi, Delhi-41

Jhot
BACT.
Principal
Dharam Deep Sec. Pub. School
J-Block, Adhyapak Nagar,
Nangloi, Delhi-110041

for
A/CHEMIST
Jayanti
Chairman
Dharam Deep Sec. Pub. School
J-Block, Adhyapak Nagar,
Nangloi, Delhi-110041

MUNICIPAL CORPORATION OF DELHI
(Office of Dy. Health Officer: Rohini Zone)
Public Health Department Sector 5 Rohini Delhi -110085
Email: dhoroheinizone15@gmail.com Tel: 011-27052106

No.-DHO/RZ/2024/905

Date: 15/02/2024

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by Asst. Public health Inspector from Public Health department Rohini Zone inspected the **DHARAM DEEP SEC. PUBLIC SCHOOL** situated at **J-Block, Adhyapak Nagar, Near narayan Dharam Kanta, Najafgarh Road, Nangloi Delhi-110041** on 13.02.2024 and found that the **DHARAM DEEP SEC. PUBLIC SCHOOL** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus.

The above certificate is valid for the period of one year from date of issue.

Dy. Health Office
Rohini Zone

Principal
DHARAM DEEP SEC. PUBLIC SCHOOL
J-Block, Adhyapak Nagar,
Near narayan Dharam Kanta,
Najafgarh Road, Nangloi
Delhi-110041


Principal
Dharam Deep Sec. Pub. School
J-Block, Adhyapak Nagar,
Nangloi, Delhi-110041


Dy. Health Officer
Dharam Deep Sec. Pub. School
J-Block, Adhyapak Nagar,
Nangloi, Delhi-110041